

Certificate of Compliance

This certificate is issued for the following:

PRESSURE REDUCING VALVES

Model 42T

Valve Size, inch NPS	End Configuration	Rated Working Pressure, psi (kPa)
3, 4, 6, 8, 10	150#/PN16 Flange	235 (1620)
3, 4, 6, 8	300#/PN25 Flange	365 (2515)
10	300#/PN25 Flange	300 (2070)

Prepared for:

Bermad Inc 9424 W Little York Rd Houston, Texas 77040-3316 USA

FM Approvals Class: 1362

Approval Granted: 11/30/2012 Approval Identification: 0003044144 FM Approvals Product Revision Report: 797-11559-268 Dated: 12/11/2012

Said Approval is subject to satisfactory field performance, continuing follow-up Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

> For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

Group Manager -Fire Protection

Norwood, MA 02062

Richard B. Dunne

FM Approvals

1151 Boston-Providence Turnpike

Member of the FM Global Group

FM Approvals®

January 3, 2013

Date



Certificate of Compliance

This certificate is issued for the following:

PRESSURE REDUCING VALVES

Model 42T

Sizes 1-1/2, 2 and 2-1/2 inch NPS

Prepared for:

Bermad CS Ltd. Mobile Post Galil Maaravi Kibbutz Evron, 22808 Israel

FM Approvals Class: 1362

Approval Identification: 0003056488 Approval Granted: April 5, 2016

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

FM Approvals[®]

Member of the FM Global Group

David B. Fuller

AVP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA