

## Type Approval Certificate Extension

*This is to certify* that Certificate No. 03/00081(E1) for the undernoted products is extended and renumbered as shown.

This certificate is issued to:

<b>PRODUCER</b>	Bermad Inc.
<b>PLACE OF PRODUCTION</b>	9424 West Little York Road TX 77040 Houston Texas United States of America (USA)
<b>DESCRIPTION</b>	Hydraulically-operated Valves
<b>TYPE</b>	700 Series
<b>SPECIFIED STANDARDS</b>	Lloyd's Register's Rules and Regulations for the Classification of Ships; ASME/ ANSI B 16.34 - 2013; Fire tested to ISO 6182 Part 5 - Requirements on test methods for deluge valves; UL-260 - Safety dry pipe and deluge valves for fire protection services.
<b>APPLICATION</b>	Fire protection systems for industrial, marine and offshore installations, for use in deluge water and foam systems, pressure control deluge, remote-operated monitors, pressure control, pressure sustaining, sprinkler systems, pressure reducing hydrants and fire pump relief systems

<b>Certificate No.</b>	03/00081(E2)
<b>Issue Date</b>	23 October 2013
<b>Expiry Date</b>	7 August 2018
<b>Sheet</b>	1 of 3

P.F. Moysey  
Marine Technology & Engineering Services,  
Lloyd's Register EMEA

*Lloyd's Register EMEA*  
71 Fenchurch Street, London EC3M 4BS

Lloyd's Register EMEA  
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

## RATINGS

Diameter (inch):	1½ to 20
(DN):	40 to 500
Design Pressure (bar):	50
Working Pressure (bar):	≤21
(PSI):	≤300
Working Temperature (°C):	≤60

### Body material:

Epoxy-coated Ductile Iron to ASTM A536 Grade 65-45-12 or GGG;

### Optional body materials:

Cast Steel to ASTM A216 Grade WCB;

Cast Steel to ASTM A352-03 Grade LCC;

Cast Stainless Steel to ASTM A351 Grade CF8M;

Cast Ni Al Bronze to ASTM B148 Grade C95800;

Duplex Stainless Steel to ASTM A890 Grade 4A and 5A;

254 SMO A351 Grade CK-3MCuN, CN-3MN;

Hastelloy C276 ASTM B336 Grade C276;

Titanium to ASTM B367 Grade C2.

## OTHER CONDITIONS

Fittings are to be selected and installed in accordance with the manufacturer's instructions and recommendations.

Material impact tests and weld non-destructive tests are to be carried out in accordance with the Rules.

Due care should be taken not to over-stress the fittings when tightening the bolts.

The piping system is to be tested in accordance with the Rules on completion of installation.

Certificate No.	03/00081(E2)
Issue Date	23 October 2013
Expiry Date	7 August 2018
Sheet	2 of 3



P.F. Moysey  
Marine Technology & Engineering Services,  
Lloyd's Register EMEA

Lloyd's Register EMEA  
71 Fenchurch Street, London EC3M 4BS

Lloyd's Register EMEA  
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



*"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."*

*The attached Design Appraisal Document No. 03/00081(E2) and its supplementary Type Approval Terms and Conditions form part of this Certificate.*

All other details remain as the previous Certificate No. 03/00081(E1) to which this extension should be attached.

<b>Certificate No.</b>	03/00081(E2)
<b>Issue Date</b>	23 October 2013
<b>Expiry Date</b>	7 August 2018
<b>Sheet</b>	3 of 3

P.F. Moysey  
Marine Technology & Engineering Services,  
Lloyd's Register EMEA

*Lloyd's Register EMEA*  
71 Fenchurch Street, London EC3M 4BS

Lloyd's Register EMEA  
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.