



---

## NSF/ANSI STANDARD 61

### Drinking Water System Components - Health Effects

---

Bermad CS Ltd

Kibbutz, Evron 25235

Israel

972-4-9855311 972-4-9855311

Facility : Kibbutz, Evron, Israel

#### Mechanical Devices - Valves

Trade Designation	Size	Water Contact Temp	Water Contact Material
700 Series Control Valves[1] [G]	1 1/2" - 32"	CLD 23	MLTPL

*[1] 700 Series Control Valves are Certified to be used with Listed control trim (pilots, fittings and tubes). The following accessories are Certified for use with valves 1 1/2" - 32". The accessories range in size from 1/8" - 1/2" diameter.*

*Male Connector 768L  
Hex, Nipple 122H  
Male Elbow 769L  
Elbow 100H  
Male Branch Tee 772L  
Branch Tee 3600H  
Tube  
Pilot BP  
Pilot PA  
Pilot HC  
Self Flushing Filter  
Y-Filter Y10  
Check Valve H410 SS  
Cock Valve S20  
Needle Valve V6 and V8 Series  
Hydraulic Relay (Amplifier)*

*[G] Product also Certified to NSF/ANSI 61, Annex G and is in compliance with California's Health & Safety Code Section 116875 (commonly known as AB1953) and Vermont Act 193. Weighted average lead content <=0.25%; Solder and flux lead content <=0.2%.*

---