

# NSF International

RECOGNIZES

POLYRAM INDUSTRIES LTD.  
ISRAEL

AS COMPLYING WITH NSF/ANSI 61.  
PRODUCTS APPEARING IN THE NSF OFFICIAL LISTING ARE  
AUTHORIZED TO BEAR THE NSF MARK.



Certification Program  
Accredited by the  
American National  
Standards Institute



Certification Program  
Accredited by the  
Standards Council  
of Canada

This certificate is the property of NSF International and must be returned upon request. To verify Certification, call 800 NSF-MARK or 734 769-8010.

February 13, 2003  
Certificate# 0T330 - 01

Mark L. Jost, Senior V.P., Water Systems  
Water Distribution Systems



## OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of  
NSF/ANSI Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on February 13, 2003.

**POLYRAM INDUSTRIES LTD.**

**RAM-ON**

**19205**

**ISRAEL**

**972 4 6499 555**

Plant At: RAM-ON, ISRAEL

**Potable Water Materials**

Trade Designation	End Use	Water	Water
		Contact Temp	Contact Material
Potable Water Materials			
Plustek PB305G33BK37 <sup>[1]</sup>	A, F, P	CLD 23	NP
Plustek PB302G50BK39P <sup>[2]</sup>	A, F, P	CLD 23	NP

[1] Certified for a maximum surface area to volume ratio of 400 square inches per liter.

[2] Certified for a maximum surface area to volume ratio of 180 square inches per liter.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.