

Our Ref: CR/JC

21 February 2001

Polyram Ram-On Industries
Moshav Ram-On
MP Megiolo 19205
Israel

Dear Sir

WATER REGULATIONS ADVISORY SCHEME
"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

NYLON

5180

Plustek PB 305G33 BK. Glass fibre reinforced black nylon. Cold water use only.

Test Reports: MA2461/P & MA2190/E Section 2

0101506

POLYRAM RAM-ON INDUSTRIES

An entry, as above, will accordingly be included in the Water Fittings and Materials Directory, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings and Materials Directory: this may be abbreviated to "Water Regulations Advisory Scheme - Approved Product" or "WRAS - Approved Product". Approval of this product does not signify the approval of its mechanical or physical properties for any use.

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in January 2006.

Yours faithfully



Chris Ramsey (Miss)
Materials Administrator
Water Regulations Advisory Scheme

Water Regulations Advisory Scheme

Pen-y-Fan

Gwent NP23

0195 248454

email: info@wras