



Certificate of Compliance

This certificate is issued for the following:

WATER PRESSURE RELIEF VALVES

Model Designation	Valve Size, inch NPS	End Configuration	Rated Working Pressure, psi (kPa)
FP430-UL/FM	2, 3, 4, 6	Flanged or Grooved (all sizes) Threaded (sizes 2 and 3 inch NPS only)	175 (1205)
FP730-UL/FM	2, 3, 4, 6, 8	Flanged or Grooved (all sizes) Threaded (sizes 2 and 3 inch NPS only)	200 (1380)
43T	1 1/2, 2, 2 1/2, 3, 4, 6, 8, 10	150#/PN16 Flange or Grooved	235 (1620)
43T	1 1/2, 2, 2 1/2, 3, 4, 6, 8	300#/PN25 Flange or Grooved	365 (2515)
43T	10	300#/PN25 Flange or Grooved	300 (2070)

Prepared for:

Victaulic-Bermad, LLC d/b/a Victaulic Bermad Technologies – VBT
9424 W Little York Rd, Houston, Texas 77040-3316

FM Approvals Class: 1361

Approval Identification: 3054929

Approval Granted: March 25, 2015

Superseded by: RR205113

Date: July 8, 2016

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller".

David B. Fuller
Group Manager –Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group