



Certificate of Compliance

This certificate is issued for the following:

PRESSURE REDUCING VALVES

Model 42T

Valve Size, inch NPS	End Configuration	Rated Working Pressure, psi (kPa)
3, 4, 6, 8, 10	150#/PN16 Flange	235 (1620)
3, 4, 6, 8	300#/PN25 Flange	365 (2515)
10	300#/PN25 Flange	300 (2070)

Prepared for:

Bermad Inc
9424 W Little York Rd
Houston, Texas 77040-3316
USA

FM Approvals Class: 1362

Approval Identification: 0003044144

Approval Granted: 11/30/2012

FM Approvals Product Revision Report: 797-11559-268

Dated: 12/11/2012

Said Approval is subject to satisfactory field performance, continuing follow-up Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in dark ink, appearing to read "Richard B. Dunne", is written over a white rectangular background.

Richard B. Dunne
Group Manager –Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

January 3, 2013

Date



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following:

PRESSURE REDUCING VALVES

Model 42T

Sizes 1-1/2, 2 and 2-1/2 inch NPS

Prepared for:

Bermad CS Ltd.
Mobile Post Galil Maaravi
Kibbutz Evron, 22808
Israel

FM Approvals Class: 1362

Approval Identification: 0003056488

Approval Granted: April 5, 2016

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D.B. Fuller'.

David B. Fuller
AVP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA

